



USB902H

DolphinView Advanced 3.6.1.0 [Expires: 2017-Dec-31]

DOLPHINVIEW DEBUGGING SOFTWARE

File View Window Help

COM3 FTWISNQTa GATEWAYCTRL 2.8.2.0 ID: 0089C2F8 [Connect [F5]] [Disconnect [F6]] Firmware Download

Node List: Workspace (Count: 2), Unassigned (Count: 5)

Node Properties for ID: 018774D4, Name: Device_74D4, Signal: -58 dbm, Telegram #: 11

EEP View: RORG: 0x06: RPS Telegram, FUNC: 0x02: Rocker Switch, 2 Rocker, TYPE: 0x01: Light and Blind Control - Application Style 1

Learn Telegram: N/A

Data Telegram Interpretation:

Telegram Log (Radio view):

Direction	Port	Date Time	ID	RORG	Data	OptionalData	Status	dbm	Subtel	DestinationID	Security	TimeDiff.
→	COM3	2017-09-25 12:06:43.44	018774D4	4BS	00 C7 62 0F		80	-41	1	FFFFFFFF	🔒	00:01:11.148
→	COM3	2017-09-25 12:06:43.49	FFAF8180	4BS	64 00 00 08		80	-41	1	FFFFFFFF	🔒	00:01:11.149
→	COM3	2017-09-25 12:06:46.42	018774D4	4BS	00 C7 62 0F		80	-41	1	FFFFFFFF	🔒	00:00:02.974
→	COM3	2017-09-25 12:06:46.45	FFAF8180	4BS	64 00 00 08		80	-41	1	FFFFFFFF	🔒	00:00:02.959
→	COM3	2017-09-25 12:07:11.49	018774D4	4BS	00 C7 63 0F		80	-42	1	FFFFFFFF	🔒	00:00:25.069
→	COM3	2017-09-25 12:07:11.54	FFAF8180	4BS	64 00 00 08		80	-41	1	FFFFFFFF	🔒	00:00:25.083
→	COM3	2017-09-25 12:07:29.15	018774D4	4BS	00 C7 62 0F		80	-41	1	FFFFFFFF	🔒	00:00:17.660
→	COM3	2017-09-25 12:07:29.19	FFAF8180	4BS	64 00 00 08		80	-41	1	FFFFFFFF	🔒	00:00:17.658
→	COM3	2017-09-25 12:07:48.85	018774D4	4BS	00 C7 63 0F		80	-41	1	FFFFFFFF	🔒	00:00:19.704
→	COM3	2017-09-25 12:07:48.88	FFAF8180	4BS	64 00 00 08		80	-41	1	FFFFFFFF	🔒	00:00:19.690
→	COM3	2017-09-25 12:08:02.17	018774D4	4BS	00 C7 63 0F		80	-58	1	FFFFFFFF	🔒	00:00:13.319
→	COM3	2017-09-25 12:08:02.21	FFAF8180	4BS	64 00 00 08		80	-42	1	FFFFFFFF	🔒	00:00:13.320

Annotations: 32 BIT DEVICE ADDRESS (points to ID column), SIGNAL STRENGTH (dbm) (points to dbm column)

DOWNLOAD DOLPHINVIEW FREE OF CHARGE

LOCATE THE USB902H WHERE SIGNAL NEEDS TO BE MONITORED:
SITE SURVEY
INSIDE CABINET

MONITOR:
DEVICE ADDRESSING
DEVICE FEEDBACK
DEVICE SIGNAL STRENGTH

SIMULATE DEVICE FOR TESTING

RUN SCRIPTS FOR TESTING UNITS



ME83XX VALVE ACTUATOR



WT913 EnOcean SENSOR