


# Wireless Changeover With Condensate Sensor

If a wireless controller is used an automatic changeover is not required. The controller knows whether the chiller or the boiler is ON. Therefore the Direct or Reverse action done by the controller will send a static position command to the actuator (ME8396).

The standard EnOcean actuator ME8396 from Spartan with a V246 valve will do the work.

The ME8396 will send feedback on position each time it reaches a new position.

If pan is wet "B", the ME8396 will close the valve and send a continuous position value of 00 at a period of 30 seconds.



WT913G-NL  
EEP: A5-10-03



V246-12F-EP3.0

